

CALIBRATION CERTIFICATE

6.10.2020

Serial Number: xxxxxx

Device type: DPTXXXXX

Range: from 0 Pa
to 1250 Pa

Input	Display	Output 0-10 V			Output 4-20 mA		
		Out (V)	Error (V)	Error (%FS)	Out (mA)	Error (mA)	Error (%FS)
0	0	0,00	0,00	0,0	4,00	0,00	0,0
0	0	5,00	0,00	0,0	12,00	0,00	0,0
0	0	10,00	0,00	0,0	20,00	0,00	0,0

Conditions:

temperature 23,2 °C

humidity 47,3 %RH

Instruments used:

	DPC 10 Pressure Calibrator: 0-1000 Pa
x	DPC 100 Pressure Calibrator: 0-10000 Pa
x	Fluke Multimeter 87V

Signature: _____

Valid 12 months